



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jul 19, 2023

Inspection Result: PARTIAL PASS

Permit Number: PRPL230827

Issuance Date: Jul 18, 2023

Property Address: 26730 COUNTY ROAD 14, ROUTT, CO 80467;

Applicant: LAB PLUMBING COMPANY

Contractor: LAB PLUMBING COMPANY 375 RIVER ROAD STEAMBOAT SPRINGS,,
CO 80487 (970) 819-9833

To construct: New home drain water and gas. Set fixtures.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: In slab drains complete and holding 5 psi.

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371