


N $\frac{1}{2}$  N $\frac{1}{2}$  Section 15, Township 6 North, Range 85 West of the  
6th P.M., Routt County, Colorado.

BE IT FURTHER RESOLVED THAT the Board of County Commissioners approves  
the Special Use Permit with the following conditions:

1. The ground in which the sewer lines are laid should be regraded to original contours and either gravelled, paved, or reseeded back to original conditions.
2. The pump station should be compatible with structures in the vicinity and completely fenced and locked to prevent intruders.
3. The proposed sewage treatment plant must be engineered to prevent effluents from being reached by floodwaters, as stipulated by the Water Control Division of the State Health Department.
4. Intermittent overflow streams and channels should be diked or bermed to prevent them from flooding into the treatment lagoons.
5. Crossing should be approved by the Railroad, and an utility crossing agreement for pipeline under the tracks should be approved prior to construction.
6. This Special Use Permit is for the life of the sewage treatment facilities.


DONE this 13th day of April, 1982.

BY THE BOARD OF COUNTY COMMISSIONERS

  
Doug Boggs, Chairman

VOTE: Doug Boggs: Aye  
Robert E. McKune: Aye  
Pat Holderness: Aye

ATTEST:

  
Eunice Dorr, County Clerk

