



**ORIGINAL PERMIT APPLICANT(S)**

BILL UHL  
 JODIE H UHL

**APPROVED WELL LOCATION**

Water Division: 6      Water District: 57  
 Designated Basin: N/A  
 Management District: N/A  
 County: ROUTT  
 Parcel Name: N/A  
 Physical Address: N/A  
 NE 1/4 SW 1/4 Section 1 Township 6.0 N Range 87.0 W Sixth P.M.

Well to be constructed on specified tract of land

**PERMIT TO CONSTRUCT A NEW WELL**

**ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT**  
**CONDITIONS OF APPROVAL**

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(I) and the policy of the State Engineer dated April 9, 1985 for appropriation of groundwater tributary to the Yampa River system.
- 4) The use of groundwater from this well is limited to drinking and sanitary facilities as described in CRS 37-92-602(1)(c), for a commercial business. Water from this well shall not be used for lawn/landscape/greenhouse irrigation, domestic animal/livestock watering, or for any other purpose outside the business building structure(s).
- 5) The pumping rate of this well shall not exceed 15 GPM.
- 6) The annual amount of groundwater to be withdrawn by this well shall not exceed 1/3 acre-foot (108,600 gallons).
- 7) Approved for a well on a tract of land of 60.35 acre(s) described as that portion of the NE 1/4 of the SW 1/4, the NW 1/4 of the SW 1/4, the SW 1/4 of the SW 1/4 and the SE 1/4 of the SW 1/4 of Section 1, Township 6 North, Range 87 West of the Sixth Principal Meridian, Routt County, more particularly described on Exhibit A in the well permit file.
- 8) A totalizing flow meter must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (recorded at least annually) and submitted to the Division Engineer upon request.
- 9) Pursuant to Rule 6.2.3 of the Water Well Construction Rules, the well construction contractor shall submit the as-built well location on work reports required by Rule 17.1 within 60 days of completion of the well. The measured location must be accurate to 200 feet of the actual location. The location information must include a GPS location (UTM coordinates) pursuant to the Division of Water Resources' guidelines.
- 10) **ADVANCE NOTICE REQUIRED** - Pursuant to Construction Rule 6.2.2.1 (2 CCR 402-2), licensed or private drillers and pump installers must provide advance notification (by 11:59 pm the day before) to the State Engineer prior to each of the following for this well: the start of well construction, the initial installation of the first permanent pump, and the initial installation of a cistern connected to the water well supply system. Any change in the date of construction/installation must be re-noticed prior to the activity (by 11:59 pm the day before). Information regarding the notification process and a link to the electronic notification form can be found on the Division of Water Resources website at [dwr.colorado.gov](http://dwr.colorado.gov)

NOTE: This permit will expire on the expiration date unless the well is constructed by that date. A Well Construction and Yield Estimate Report (GWS-31) must be submitted to the Division of Water Resources to verify the well has been constructed. An extension of the expiration date may be available. Contact the DWR for additional information or refer to the extension request form (GWS-64) available at: [dwr.colorado.gov](http://dwr.colorado.gov)

NOTICE: This permit has been approved subject to the following changes: The quarter/quarter and quarter section were determined from UTM coordinate values provided with the permit application. You are hereby notified that you have the right to appeal the issuance of this permit, by filing a written request with this office within sixty (60) days of the date of issuance, pursuant to the State Administrative Procedures Act. (See Section 24-4-104 through 106, C.R.S.)

