

AZTEC DRILLING COMPANY

PO BOX 772771 * STEAMBOAT SPRINGS, CO 80477 * 970 879 5252

FLOW TEST DATA

Date Tested: 9/20/12

Property Location: 32505 RCR 20

Steamboat Springs, CO

meter start: 9143 Jace Romick Property

meter:	meter:	meter:
<u>9175</u> 5 min <u>6.4</u> gpm	65 min _____ gpm	125 min _____ gpm
<u>9210</u> 10 min <u>7.0</u> gpm	<u>9594</u> 70 min <u>5.8</u> gpm	130 min _____ gpm
<u>9246</u> 15 min <u>7.2</u> gpm	75 min _____ gpm	135 min _____ gpm
<u>9282</u> 20 min <u>7.2</u> gpm	<u>9635</u> 80 min <u>4.1</u> gpm	140 min _____ gpm
<u>9317</u> 25 min <u>7.0</u> gpm	83 min * changed cartridge filter	
<u>9350</u> 30 min <u>6.6</u> gpm	<u>9651</u> 85 min _____ gpm	150 min _____ gpm
<u>9383</u> 35 min <u>6.6</u> gpm	<u>9683</u> 90 min <u>6.4</u> gpm	155 min _____ gpm
<u>9415</u> 40 min <u>6.4</u> gpm	<u>9716</u> 95 min <u>6.6</u> gpm	160 min _____ gpm
_____ 45 min _____ gpm	<u>9748</u> 100 min <u>6.4</u> gpm	165 min _____ gpm
<u>9477</u> 50 min <u>6.2</u> gpm	<u>9777</u> 105 min <u>5.8</u> gpm	170 min _____ gpm
_____ 55 min _____ gpm	<u>9804</u> 110 min <u>5.4</u> gpm	175 min _____ gpm
<u>9536</u> 60 min <u>5.9</u> gpm	120 min _____ gpm	180 min _____ gpm

Average Flow Rate _____ gpm Total Discharge 661 gallons

** These data do not necessarily reflect the production rate of the well.

* 110 minute mark= increased sediment/
decreased flow thru filter/ pumping
terminated

Aztec Drilling Company
Lic #1198

AZTEC DRILLING COMPANY

PO BOX 772771 * STEAMBOAT SPRINGS, CO 80477 * 970 879 5252

date: 9/17/13							R Martyn	
meter start: 9336			FLOW TEST DATA					
starting water level:								
meter:	min:	gpm:	level:		meter:	min:	gpm:	level:
9342	1	6.0				170		
9348	2	6.0				175		
	3					180		
	4					185		
9373	5	7.4				190		
	6					195		
	7					200		
	8					205		
	9					210		
9419	10	9.2				215		
9467	15	9.6				220		
	20					225		
9559	25	9.2				230		
9605	30	9.2				235		
9651	35	9.2				240		
9699	40	9.6				245		
9745	45	9.2				250		
9792	50	9.4				255		
9839	55	9.4				260		
9886	60	9.4				265		
9933	65	9.4				270		
9979	70	9.2				275		
	75					280		
10073	80	9.4				285		
	85					290		
10167	90	9.4				295		
	95					300		
10260	100	9.3				305		
	105					310		
10354	110	9.4				315		
	115					320		
10448	120	9.4				325		
	125					330		
	130					335		
	135					340		
	140					345		
	145					350		
	150					355		
	155					360		
	160					365		
	165					370		

AZTEC DRILLING COMPANY

PO BOX 772771 * STEAMBOAT SPRINGS,CO 80477 * 970 879 5252

Date: 10/25/17

32305 RCR 20 R Martyn

Meter Start: 1773

FLOW TEST DATA

meter:	min:	gpm:	meter:	min:	gpm:	meter:	min:	gpm:
1781	1	8.0						
1790	2	9.0						
1799	3	9.0						
1808	4	9.0						
1817	5	9.0						
1827	6	10.0						
1836	7	9.0						
1846	8	10.0						
1856	9	10.0						
1866	10	10.0						
1915	15	9.8						
1964	20	9.8						
2013	25	9.8						
2062	30	9.8						
2160	40	9.8						
2259	50	9.9						
2356	60	9.7						
2455	70	9.9						
2554	80	9.9						
2652	90	9.8						
2751	100	9.9						
2850	110	9.9						
2949	120	9.9						

TOTAL DISCHARGE =	1176 gallons
-------------------	--------------

AZTEC DRILLING COMPANY

PO BOX 772771 * STEAMBOAT SPRINGS,CO 80477 * 970 879 5252

Date: 9/17/19

32305 RCR 20 FROLIK

Meter Start: 2829

FLOW TEST DATA

meter:	min:	gpm:	meter:	min:	gpm:	meter:	min:	gpm:
2835	1	6.0						
2843	2	8.0						
2869	5	8.7						
2886	7	8.5						
2913	10	9.0						
2959	15	9.2						
3005	20	9.2						
3050	25	9.0						
3096	30	9.2						
3142	35	9.2						
3188	40	9.2						
3234	45	9.2						
3279	50	9.0						
3325	55	9.2						
3371	60	9.2						
3462	70	9.1						
3554	80	9.2						
3645	90	9.1						
3737	100	9.2						
3829	110	9.2						
3921	120	9.2						

TOTAL DISCHARGE =	1092 GALLONS
-------------------	--------------

